

SAMPLE REPORT

TANK GENERATOR REPORT
Last 30 Days

Feb 27, 2026, 9:33:44 AM

Table of Contents

Table of Contents	2
Diesel	3

Diesel

	Product : Midgrade				Capacity : 5000.0 gal				
	Time	Gross Volume	Net Volume	Rate	Ullage Volume	Product Level	Temperature	Water Level	Water Volume
		(gal)	(gal)	(gph)	(gal)	(in)	(°F)	(in)	(gal)
Started	4/26/23 14:01	642.6	637.2		2,637.0	6.88	72.0	0.45	45.4
Stopped	4/26/23 14:02	2,167.1	2,148.7		1,112.3	22.13	72.0	0.46	45.6
Usage				N/A (delivery)					
Started	4/5/23 9:07	2,197.2	2,177.2		1,086.1	22.39	72.8	0.42	41.6
Stopped	4/5/23 9:08	2,197.1	2,177.1		1,086.2	22.39	72.9	0.42	41.6
Usage		0.1	0.1	5.86					