

SAMPLE REPORT

**TANK TEST REPORT**  
**Last 30 Days**

Feb 23, 2026, 12:47:38 PM

## Table of Contents

Table of Contents	2
SCALD Tests	3
Unleaded	3
Premium	3
Static Tests	6
Unleaded	6
Premium	6

**SCALD Tests****Unleaded**

Product : Unleaded				Capacity : 19,951.0 gal			
Start Time	End Time	Result	Slope	Test Time	Average Volume	Test Confidence	Volume Qualify
			(gal/hour)	(min)	(gal)		
01/27/2026 03:51	02/11/2026 03:54	Pass	-0.08	377	14,261.4	95%	14%
01/23/2026 04:00	02/07/2026 04:09	Pass	-0.10	461	14,127.8	95%	14%
01/19/2026 04:00	02/03/2026 04:10	Pass	-0.06	377	12,482.3	95%	14%
01/11/2026 04:04	01/26/2026 04:24	Pass	-0.10	391	12,246.1	95%	14%

**Premium**

Product : Premium 91E				Capacity : 8,531.0 gal			
Start Time	End Time	Result	Slope	Test Time	Average Volume	Test Confidence	Volume Qualify
			(gal/hour)	(min)	(gal)		
02/11/2026 03:28	02/23/2026 03:44	Pass	0.00	7,340	3,941.4	95%	14%
02/10/2026 03:18	02/22/2026 03:38	Pass	0.00	7,166	3,913.5	95%	14%
02/09/2026 02:55	02/21/2026 03:26	Pass	-0.00	7,269	3,868.7	95%	14%
02/08/2026 02:11	02/20/2026 03:10	Pass	-0.00	7,671	3,888.3	95%	14%
02/07/2026 02:09	02/19/2026 02:25	Pass	-0.00	7,328	3,988.4	95%	14%
02/06/2026 01:53	02/18/2026 02:18	Pass	0.00	7,455	4,136.0	95%	14%
02/05/2026 01:47	02/17/2026 02:09	Pass	0.00	7,538	4,271.5	95%	14%
02/04/2026 01:36	02/16/2026 01:54	Pass	-0.00	7,896	4,367.9	95%	14%
02/03/2026 01:40	02/15/2026 01:51	Pass	-0.00	8,248	4,437.4	95%	14%
02/02/2026 01:23	02/14/2026 01:42	Pass	0.00	8,283	4,523.0	95%	14%
02/01/2026 01:04	02/13/2026 01:25	Pass	0.00	8,557	4,593.7	95%	14%
01/31/2026 00:49	02/12/2026 01:12	Pass	-0.00	8,331	4,658.9	95%	14%
01/30/2026 00:37	02/11/2026 01:00	Pass	-0.00	8,371	4,720.3	95%	14%
01/29/2026 00:40	02/10/2026 00:50	Pass	-0.00	8,255	4,795.1	95%	14%
01/28/2026 00:41	02/09/2026 00:48	Pass	-0.00	7,313	4,876.9	95%	14%

Product : Premium 91E				Capacity : 8,531.0 gal			
Start Time	End Time	Result	Slope (gal/hour)	Test Time (min)	Average Volume (gal)	Test Confidence	Volume Qualify
01/27/2026 00:41	02/08/2026 00:47	Pass	-0.00	7,274	4,960.5	95%	14%
01/26/2026 00:28	02/07/2026 00:45	Pass	0.00	7,149	5,006.0	95%	14%
01/25/2026 00:17	02/06/2026 00:29	Pass	-0.00	6,670	5,069.0	95%	14%
01/23/2026 23:51	02/05/2026 00:23	Pass	-0.00	6,052	5,110.8	95%	14%
01/22/2026 23:53	02/04/2026 00:11	Pass	0.00	5,705	4,990.7	95%	14%
01/21/2026 23:22	02/02/2026 23:55	Pass	0.00	5,486	4,681.6	95%	14%
01/20/2026 23:06	02/01/2026 23:38	Pass	0.00	5,490	4,275.4	95%	14%
01/19/2026 21:52	01/31/2026 23:18	Pass	0.01	5,305	3,985.1	95%	14%
01/18/2026 20:51	01/30/2026 22:01	Pass	0.01	5,215	3,778.1	95%	14%
01/17/2026 19:15	01/29/2026 21:06	Pass	0.01	4,968	3,546.1	95%	14%
01/16/2026 19:12	01/28/2026 19:24	Pass	0.01	4,845	3,241.8	95%	14%
01/15/2026 18:28	01/27/2026 19:15	Pass	0.01	5,186	2,852.5	95%	14%
01/14/2026 18:34	01/26/2026 18:44	Pass	0.01	4,474	2,499.7	95%	14%
01/13/2026 18:10	01/25/2026 18:43	Pass	0.01	4,549	2,325.5	95%	14%
01/11/2026 20:54	01/24/2026 18:13	Pass	0.01	5,473	2,330.9	95%	14%

### Static Tests

#### Unleaded

Product : Unleaded								Capacity : 19,951.0 gal					
Time	Gross Volume	Net Volume	Product Level	Temperature	Water Level	Water Volume	Last Delivery	Test Type	Slope	Result	Threshold	Capacity	
	(gal)	(gal)	(in)	(°F)	(in)	(gal)			(gal/hour)		(gal/hour)	(%)	
<b>Begin Test:</b> 2/15/26 21:59	6,796.675	6,853.666	45.1276	48.10	0.0000	0.000	2/15/26 12:06	Monthly (0.20 gph)	-0.00	Pass	0.20	34.1	
<b>End Test:</b> 2/16/26 05:57	6,796.185	6,853.816	45.1252	47.96	0.0000	0.000							
<b>Hourly:</b> 2/16/26 05:00		6,853.707	45.1248	47.97									
2/16/26 04:00		6,853.617	45.1248	47.98									
2/16/26 03:00		6,853.769	45.1258	48.00									
2/16/26 02:00		6,853.694	45.1258	48.01									
2/16/26 01:00		6,853.760	45.1264	48.03									
2/16/26 00:00		6,853.716	45.1268	48.05									
2/15/26 23:00		6,853.706	45.1273	48.07									

#### Premium

Product : Premium								Capacity : 8,531.0 gal					
Time	Gross Volume	Net Volume	Product Level	Temperature	Water Level	Water Volume	Last Delivery	Test Type	Slope	Result	Threshold	Capacity	
	(gal)	(gal)	(in)	(°F)	(in)	(gal)			(gal/hour)		(gal/hour)	(%)	
<b>Begin Test:</b> 2/8/26 21:59	4,184.412	4,232.024	32.1642	43.83	0.0000	0.000	2/7/27 09:57	Monthly (0.20 gph)	-0.07	Pass	0.20	21.0	
<b>End Test:</b> 2/9/26 05:07	4,185.371	4,231.519	32.1694	44.34	0.0000	0.000							
<b>Hourly:</b> 2/9/26 05:00		4,231.459	32.1689	44.33									
2/9/26 04:00		4,231.572	32.1685	44.26									
2/9/26 03:00		4,231.547	32.1674	44.19									
2/9/26 02:00		4,231.556	32.1663	44.13									
2/9/26 01:00		4,231.638	32.1656	44.06									
2/9/26 00:00		4,231.742	32.1651	43.99									
2/8/26 23:00		4,231.827	32.1644	43.91									